

Sample Identification # and Location	Location Info	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action	Units
BE1		6/25/2024 08:30	7/10/2024 11:04	70303002001	Lead	<1.0	5	ug/L
BE1A		6/25/2024 08:30	7/10/2024 11:11	70303002002	Lead	1.0	5	ug/L
BE2		6/25/2024 08:31	7/10/2024 11:16	70303002003	Lead	1.4	5	ug/L
BE2A		6/25/2024 08:31	7/10/2024 11:17	70303002004	Lead	2.1	5	ug/L
BE3		6/25/2024 08:33	7/10/2024 11:19	70303002005	Lead	1.2	5	ug/L
BE3A		6/25/2024 08:33	7/10/2024 11:21	70303002006	Lead	<1.0	5	ug/L
BE4		6/25/2024 08:35	7/10/2024 11:22	70303002007	Lead	<1.0	5	ug/L
BE4A		6/25/2024 08:35	7/10/2024 11:24	70303002008	Lead	<1.0	5	ug/L
BE5		6/25/2024 08:36	7/10/2024 11:25	70303002009	Lead	2.0	5	ug/L
BE5A		6/25/2024 08:36	7/10/2024 11:30	70303002010	Lead	4.5	5	ug/L
BE6	Room 109 Drinking Fountain	6/25/2024 08:38	7/10/2024 11:32	70303002011	Lead	27.4	5	ug/L
BE6A		6/25/2024 08:38	7/10/2024 11:33	70303002012	Lead	1.3	5	ug/L
BE7		6/25/2024 08:39	7/10/2024 11:35	70303002013	Lead	2.0	5	ug/L
BE7A		6/25/2024 08:39	7/10/2024 11:36	70303002014	Lead	2.2	5	ug/L
BE9		6/25/2024 08:42	7/10/2024 11:38	70303002015	Lead	2.1	5	ug/L
BE10		6/25/2024 08:43	7/10/2024 11:39	70303002016	Lead	<1.0	5	ug/L
BE10A		6/25/2024 08:43	7/10/2024 11:41	70303002017	Lead	<1.0	5	ug/L
BE11	Room 125 Drinking Fountain	6/25/2024 08:45	7/10/2024 11:42	70303002018	Lead	12.7	5	ug/L
BE11A		6/25/2024 08:45	7/10/2024 11:44	70303002019	Lead	2.0	5	ug/L
BE12	Room 129 Drinking Fountain	6/25/2024 08:47	7/10/2024 11:49	70303002020	Lead	5.7	5	ug/L
BE12A		6/25/2024 08:47	7/10/2024 11:53	70303002021	Lead	2.2	5	ug/L
BE13		6/25/2024 08:48	7/10/2024 11:58	70303002022	Lead	<1.0	5	ug/L
BE14		6/25/2024 08:50	7/10/2024 12:03	70303002023	Lead	4.6	5	ug/L
BE14A		6/25/2024 08:50	7/10/2024 12:07	70303002024	Lead	3.7	5	ug/L
BE15		6/25/2024 08:52	7/10/2024 12:09	70303002025	Lead	<1.0	5	ug/L
BE15A		6/25/2024 08:52	7/10/2024 12:10	70303002026	Lead	1.6	5	ug/L
BE16		6/25/2024 08:57	7/10/2024 12:12	70303002027	Lead	<1.0	5	ug/L
BE16A		6/25/2024 08:57	7/10/2024 12:13	70303002028	Lead	<1.0	5	ug/L
BE17	Room 140 Drinking Fountain	6/25/2024 08:55	7/10/2024 12:15	70303002029	Lead	5.6	5	ug/L
BE17A		6/25/2024 08:55	7/10/2024 12:17	70303002030	Lead	2.6	5	ug/L
BE18		6/25/2024 09:02	7/10/2024 12:18	70303002031	Lead	<1.0	5	ug/L
BE18A		6/25/2024 09:02	7/10/2024 12:20	70303002032	Lead	1.1	5	ug/L
BE19	Room 142 Drinking Fountain	6/25/2024 08:59	7/10/2024 12:21	70303002033	Lead	17.2	5	ug/L
BE19A		6/25/2024 08:59	7/10/2024 12:26	70303002034	Lead	3.2	5	ug/L
BE20		6/25/2024 09:03	7/10/2024 12:27	70303002035	Lead	<1.0	5	ug/L
BE20A		6/25/2024 09:03	7/10/2024 12:29	70303002036	Lead	<1.0	5	ug/L
BE21		6/25/2024 09:05	7/10/2024 12:31	70303002037	Lead	1.1	5	ug/L
BE21A		6/25/2024 09:05	7/10/2024 12:32	70303002038	Lead	2.9	5	ug/L
BE22		6/25/2024 09:06	7/10/2024 12:34	70303002039	Lead	<1.0	5	ug/L
BE23		6/25/2024 09:07	7/10/2024 12:35	70303002040	Lead	<1.0	5	ug/L
BE24	Room 146 Drinking Fountain	6/25/2024 09:08	7/10/2024 12:40	70303002041	Lead	5.9	5	ug/L
BE24A	Room 146 Classroom Sink	6/25/2024 09:08	7/10/2024 12:48	70303002042	Lead	7.0	5	ug/L
BE25		6/25/2024 09:10	7/10/2024 12:52	70303002043	Lead	1.2	5	ug/L
BE25A		6/25/2024 09:10	7/10/2024 12:54	70303002044	Lead	1.1	5	ug/L
BE26A		6/25/2024 09:11	7/10/2024 12:55	70303002045	Lead	3.2	5	ug/L
BE27		6/25/2024 09:13	7/10/2024 12:57	70303002046	Lead	<1.0	5	ug/L
BE27A		6/25/2024 09:13	7/10/2024 12:58	70303002047	Lead	<1.0	5	ug/L
BE28	Cafeteria Kitchen Sink	6/25/2024 09:15	7/10/2024 18:25	70303002048	Lead	1,090	5	ug/L
BE29		6/25/2024 09:16	7/10/2024 13:05	70303002049	Lead	4.3	5	ug/L

NYSDOH Action Level for Lead In Schools of 5 ppb