

Sample Identification # and Location	Location Info	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action	Units
CE-1		6/25/2024 07:16	7/9/2024 18:50	70303001001	Lead	1.0	5	ug/L
CE-2		6/25/2024 07:17	7/9/2024 18:52	70303001002	Lead	<1.0	5	ug/L
CE-2A		6/25/2024 07:17	7/9/2024 18:57	70303001003	Lead	3.5	5	ug/L
CE-2B		6/25/2024 07:17	7/9/2024 18:58	70303001004	Lead	<1.0	5	ug/L
CE-3		6/25/2024 07:18	7/9/2024 19:00	70303001005	Lead	4.4	5	ug/L
CE-4		6/25/2024 07:19	7/9/2024 19:01	70303001006	Lead	1.0	5	ug/L
CE-6	Room 138 Drinking Fountain	6/25/2024 07:24	7/9/2024 19:06	70303001007	Lead	13.0	5	ug/L
CE-8		6/25/2024 07:29	7/9/2024 19:10	70303001008	Lead	3.4	5	ug/L
CE-8A		6/25/2024 07:29	7/9/2024 19:18	70303001009	Lead	1.5	5	ug/L
CE-11		6/25/2024 07:36	7/9/2024 19:20	70303001010	Lead	<1.0	5	ug/L
CE-11A		6/25/2024 07:36	7/9/2024 19:21	70303001011	Lead	1.2	5	ug/L
CE-13		6/25/2024 07:45	7/9/2024 19:23	70303001012	Lead	<1.0	5	ug/L
CE-13A		6/25/2024 07:45	7/9/2024 19:25	70303001013	Lead	<1.0	5	ug/L
CE-14		6/25/2024 07:49	7/9/2024 19:26	70303001014	Lead	<1.0	5	ug/L
CE-14A		6/25/2024 07:49	7/9/2024 19:28	70303001015	Lead	<1.0	5	ug/L
CE-15		6/25/2024 07:52	7/9/2024 19:29	70303001016	Lead	<1.0	5	ug/L
CE-15A		6/25/2024 07:52	7/9/2024 19:34	70303001017	Lead	<1.0	5	ug/L
CE-16		6/25/2024 07:56	7/9/2024 19:35	70303001018	Lead	<1.0	5	ug/L
CE-16A		6/25/2024 07:56	7/9/2024 19:37	70303001019	Lead	<1.0	5	ug/L
CE-17		6/25/2024 08:01	7/9/2024 19:39	70303001020	Lead	<1.0	5	ug/L
CE-17A		6/25/2024 08:01	7/9/2024 19:40	70303001021	Lead	1.2	5	ug/L
CE-18		6/25/2024 08:04	7/9/2024 19:42	70303001022	Lead	<1.0	5	ug/L
CE-18A		6/25/2024 08:04	7/9/2024 19:43	70303001023	Lead	1.0	5	ug/L
CE-20		6/25/2024 08:09	7/9/2024 19:45	70303001024	Lead	2.3	5	ug/L
CE-20A		6/25/2024 08:09	7/9/2024 19:46	70303001025	Lead	2.5	5	ug/L
CE-21		6/25/2024 08:11	7/10/2024 18:30	70303001026	Lead	<1.0	5	ug/L
CE-21A		6/25/2024 08:11	7/10/2024 10:21	70303001027	Lead	1.9	5	ug/L
CE-22		6/25/2024 08:15	7/10/2024 10:26	70303001028	Lead	<1.0	5	ug/L
CE-22A		6/25/2024 08:15	7/10/2024 10:28	70303001029	Lead	<1.0	5	ug/L
CE-23		6/25/2024 08:17	7/10/2024 10:29	70303001030	Lead	<1.0	5	ug/L
CE-23A		6/25/2024 08:17	7/10/2024 10:34	70303001031	Lead	<1.0	5	ug/L
CE-24		6/25/2024 08:21	7/10/2024 10:35	70303001032	Lead	<1.0	5	ug/L
CE-24A		6/25/2024 08:21	7/10/2024 10:37	70303001033	Lead	1.1	5	ug/L
CE-25		6/25/2024 08:24	7/10/2024 10:39	70303001034	Lead	<1.0	5	ug/L
CE-25A		6/25/2024 08:24	7/10/2024 10:40	70303001035	Lead	1.2	5	ug/L
CE-26		6/25/2024 08:29	7/10/2024 10:42	70303001036	Lead	<1.0	5	ug/L
CE-26A		6/25/2024 08:29	7/10/2024 10:43	70303001037	Lead	<1.0	5	ug/L
CE-27		6/25/2024 08:31	7/10/2024 10:45	70303001038	Lead	<1.0	5	ug/L
CE-27A		6/25/2024 08:31	7/10/2024 10:46	70303001039	Lead	<1.0	5	ug/L
CE-28		6/25/2024 08:34	7/10/2024 10:48	70303001040	Lead	2.3	5	ug/L
CE-29	Kitchen Faucet	6/25/2024 08:34	7/10/2024 10:53	70303001041	Lead	15.7	5	ug/L
CE-31		6/25/2024 07:15	7/10/2024 10:54	70303001042	Lead	3.7	5	ug/L
CE-36		6/25/2024 08:41	7/10/2024 10:56	70303001043	Lead	<1.0	5	ug/L
CE-12		6/25/2024 07:39	7/10/2024 10:57	70303001044	Lead	<1.0	5	ug/L
CE-12A		6/25/2024 07:39	7/10/2024 10:59	70303001045	Lead	<1.0	5	ug/L

NYSDOH Action Level for Lead In Schools of 5 ppb