

Sample Identification # and Location	Location Info	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action	Units
GE2		6/25/2024 07:16	7/9/2024 13:30	70302927001	Lead	1.3	5	ug/L
GE3		6/25/2024 07:16	7/9/2024 13:31	70302927002	Lead	<1.0	5	ug/L
GE4		6/25/2024 07:14	7/9/2024 13:33	70302927003	Lead	<1.0	5	ug/L
GE5		6/25/2024 07:14	7/9/2024 13:35	70302927004	Lead	<1.0	5	ug/L
GE6		6/25/2024 07:12	7/9/2024 13:36	70302927005	Lead	1.0	5	ug/L
GE7		6/25/2024 07:10	7/9/2024 13:38	70302927006	Lead	2.2	5	ug/L
GE8		6/25/2024 07:08	7/9/2024 13:39	70302927007	Lead	1.4	5	ug/L
GE9		6/25/2024 07:07	7/9/2024 13:41	70302927008	Lead	1.7	5	ug/L
GE10		6/25/2024 07:06	7/9/2024 13:42	70302927009	Lead	1.4	5	ug/L
GE11		6/25/2024 07:11	7/9/2024 13:50	70302927010	Lead	1.5	5	ug/L
GE12		6/25/2024 07:03	7/9/2024 13:55	70302927011	Lead	3.8	5	ug/L
GE15		6/25/2024 07:18	7/9/2024 13:59	70302927012	Lead	<1.0	5	ug/L
GE16		6/25/2024 07:18	7/9/2024 14:01	70302927013	Lead	<1.0	5	ug/L
GE22	Kitchen Sink	6/25/2024 07:24	7/9/2024 14:02	70302927014	Lead	6.7	5	ug/L
GE23		6/25/2024 07:25	7/9/2024 14:07	70302927015	Lead	1.5	5	ug/L
GE24		6/25/2024 07:25	7/9/2024 14:09	70302927016	Lead	1.8	5	ug/L
GE25	Kitchen Handwashing Sink	6/25/2024 07:25	7/9/2024 14:10	70302927017	Lead	10.5	5	ug/L
GE27		6/25/2024 07:22	7/9/2024 14:12	70302927018	Lead	2.2	5	ug/L
GE30		6/25/2024 07:31	7/9/2024 14:13	70302927019	Lead	1.1	5	ug/L
GE32		6/25/2024 07:35	7/9/2024 14:15	70302927020	Lead	<1.0	5	ug/L
GE33		6/25/2024 07:37	7/9/2024 14:16	70302927021	Lead	2.0	5	ug/L
GE34		6/25/2024 07:39	7/9/2024 14:18	70302927022	Lead	<1.0	5	ug/L
GE35		6/25/2024 07:40	7/9/2024 14:19	70302927023	Lead	2.2	5	ug/L
GE36	Classroom Sink	6/25/2024 07:42	7/9/2024 14:21	70302927024	Lead	5.3	5	ug/L
GE37		6/25/2024 07:44	7/9/2024 14:26	70302927025	Lead	<1.0	5	ug/L
GE38		6/25/2024 07:46	7/9/2024 14:27	70302927026	Lead	<1.0	5	ug/L
GE39		6/25/2024 07:47	7/9/2024 14:29	70302927027	Lead	1.2	5	ug/L
GE41		6/25/2024 07:49	7/9/2024 14:30	70302927028	Lead	<1.0	5	ug/L
GE42		6/25/2024 07:50	7/9/2024 14:32	70302927029	Lead	<1.0	5	ug/L
GE43		6/25/2024 07:51	7/9/2024 15:55	70302927030	Lead	<1.0	5	ug/L
GE44	Room 148 Drinking Fountain	6/25/2024 07:51	7/9/2024 16:00	70302927031	Lead	8.4	5	ug/L
GE45		6/25/2024 07:52	7/9/2024 16:01	70302927032	Lead	1.7	5	ug/L
GE46		6/25/2024 07:52	7/9/2024 16:03	70302927033	Lead	2.2	5	ug/L
GE47		6/25/2024 07:27	7/9/2024 16:07	70302927034	Lead	1.0	5	ug/L
GE48		6/25/2024 07:28	7/9/2024 16:09	70302927035	Lead	<1.0	5	ug/L
GE49		6/25/2024 07:28	7/9/2024 16:11	70302927036	Lead	1.1	5	ug/L
GE52		6/25/2024 07:12	7/9/2024 16:12	70302927037	Lead	2.0	5	ug/L
GE54		6/25/2024 07:08	7/9/2024 16:14	70302927038	Lead	<1.0	5	ug/L
GE55		6/25/2024 07:07	7/9/2024 16:15	70302927039	Lead	<1.0	5	ug/L
GE53		6/25/2024 07:10	7/9/2024 16:17	70302927040	Lead	1.6	5	ug/L
GE57		6/25/2024 07:03	7/9/2024 16:18	70302927041	Lead	<1.0	5	ug/L
GE60		6/25/2024 07:55	7/9/2024 16:20	70302927042	Lead	<1.0	5	ug/L
GE61		6/25/2024 07:55	7/9/2024 16:22	70302927043	Lead	<1.0	5	ug/L
GE63		6/25/2024 07:57	7/9/2024 16:26	70302927044	Lead	<1.0	5	ug/L
GE64		6/25/2024 07:57	7/9/2024 16:28	70302927045	Lead	<1.0	5	ug/L
GE56		6/25/2024 07:06	7/9/2024 16:29	70302927046	Lead	<1.0	5	ug/L
GE66		6/25/2024 07:34	7/9/2024 16:31	70302927047	Lead	<1.0	5	ug/L
GE68		6/25/2024 07:42	7/9/2024 16:33	70302927048	Lead	<1.0	5	ug/L
GE74		6/25/2024 07:44	7/9/2024 16:34	70302927049	Lead	1.3	5	ug/L
GE75		6/25/2024 07:40	7/9/2024 16:45	70302927050	Lead	<1.0	5	ug/L
GE76		6/25/2024 07:37	7/9/2024 16:50	70302927051	Lead	1.6	5	ug/L
GE77		6/25/2024 07:35	7/9/2024 16:51	70302927052	Lead	<1.0	5	ug/L
GE78		6/25/2024 07:31	7/9/2024 16:53	70302927053	Lead	<1.0	5	ug/L
GE83		6/25/2024 07:22	7/9/2024 16:54	70302927054	Lead	<1.0	5	ug/L
GE84		6/25/2024 07:20	7/9/2024 16:56	70302927055	Lead	1.5	5	ug/L
GE85		6/25/2024 07:20	7/9/2024 16:58	70302927056	Lead	1.6	5	ug/L

