

Sample Identification # and Location	Location Info	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action	Units
1M-1		6/25/2024 11:10	7/9/2024 12:37	70302922001	Lead	<1.0	5	ug/L
1M-1A		6/25/2024 11:10	7/9/2024 12:39	70302922002	Lead	<1.0	5	ug/L
1M-3A		6/25/2024 11:13	7/9/2024 12:40	70302922003	Lead	<1.0	5	ug/L
1M-3B		6/25/2024 11:13	7/9/2024 12:42	70302922004	Lead	<1.0	5	ug/L
1M-4		6/25/2024 11:18	7/9/2024 12:43	70302922005	Lead	<1.0	5	ug/L
1M-5A		6/25/2024 11:18	7/9/2024 12:45	70302922006	Lead	<1.0	5	ug/L
1M-5B		6/25/2024 11:18	7/9/2024 12:46	70302922007	Lead	<1.0	5	ug/L
1M-6		6/25/2024 11:20	7/9/2024 12:48	70302922008	Lead	<1.0	5	ug/L
1M-7A		6/25/2024 11:20	7/9/2024 12:53	70302922009	Lead	<1.0	5	ug/L
1M-7B		6/25/2024 11:20	7/9/2024 12:54	70302922010	Lead	<1.0	5	ug/L
1M-8		6/25/2024 11:25	7/9/2024 12:56	70302922011	Lead	1.3	5	ug/L
1M-9A		6/25/2024 11:27	7/9/2024 13:00	70302922012	Lead	<1.0	5	ug/L
1M-9B		6/25/2024 11:27	7/9/2024 13:05	70302922013	Lead	<1.0	5	ug/L
1M-10	Kitchen Sink by Walk-In Cooler	6/25/2024 11:30	7/9/2024 13:13	70302922014	Lead	6.6	5	ug/L
1M-11A		6/25/2024 11:32	7/9/2024 13:14	70302922015	Lead	3.4	5	ug/L
1M-11B	Left Kitchen Sink (Pot Wash)	6/25/2024 11:32	7/9/2024 13:16	70302922016	Lead	6.9	5	ug/L
1M-12		6/25/2024 11:35	7/9/2024 13:17	70302922017	Lead	<1.0	5	ug/L
1M-13A		6/25/2024 11:35	7/9/2024 13:19	70302922018	Lead	<1.0	5	ug/L
1M-13B		6/25/2024 11:35	7/9/2024 13:21	70302922019	Lead	<1.0	5	ug/L
1M-14		6/25/2024 11:37	7/9/2024 13:22	70302922020	Lead	<1.0	5	ug/L
1M-15A		6/25/2024 11:37	7/9/2024 13:24	70302922021	Lead	<1.0	5	ug/L
1M-15B		6/25/2024 11:37	7/9/2024 13:25	70302922022	Lead	<1.0	5	ug/L

NYSDOH Action Level for Lead In Schools of 5 ppb