

Sample Identification # and Location	Location Info	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action	Units
RE-1		6/25/2024 09:06	7/9/2024 16:59	70302936001	Lead	<1.0	5	ug/L
RE-1A		6/25/2024 09:06	7/9/2024 17:04	70302936002	Lead	<1.0	5	ug/L
RE-2		6/25/2024 09:08	7/9/2024 17:05	70302936003	Lead	<1.0	5	ug/L
RE-2A		6/25/2024 09:08	7/9/2024 17:07	70302936004	Lead	3.1	5	ug/L
RE-3		6/25/2024 09:11	7/9/2024 17:09	70302936005	Lead	2.3	5	ug/L
RE-3A		6/25/2024 09:11	7/9/2024 17:10	70302936006	Lead	2.2	5	ug/L
RE-4		6/25/2024 09:13	7/9/2024 17:12	70302936007	Lead	3.4	5	ug/L
RE-4A		6/25/2024 09:13	7/9/2024 17:13	70302936008	Lead	3.0	5	ug/L
RE-5	Room 107 Drinking Fountain	6/25/2024 09:15	7/9/2024 17:15	70302936009	Lead	6.2	5	ug/L
RE-5A		6/25/2024 09:15	7/9/2024 17:16	70302936010	Lead	3.8	5	ug/L
RE-6		6/25/2024 09:17	7/9/2024 17:18	70302936011	Lead	1.3	5	ug/L
RE-6A		6/25/2024 09:17	7/9/2024 17:23	70302936012	Lead	1.2	5	ug/L
RE-7		6/25/2024 09:20	7/9/2024 17:24	70302936013	Lead	1.6	5	ug/L
RE-7A		6/25/2024 09:20	7/9/2024 17:29	70302936014	Lead	1.5	5	ug/L
RE-8		6/25/2024 09:22	7/9/2024 17:33	70302936015	Lead	2.5	5	ug/L
RE-8A		6/25/2024 09:22	7/9/2024 17:41	70302936016	Lead	1.2	5	ug/L
RE-9		6/25/2024 09:26	7/9/2024 17:43	70302936017	Lead	2.5	5	ug/L
RE-9A		6/25/2024 09:26	7/9/2024 17:44	70302936018	Lead	2.1	5	ug/L
RE-11		6/25/2024 09:35	7/9/2024 17:46	70302936019	Lead	3.6	5	ug/L
RE-12		6/25/2024 09:42	7/9/2024 17:48	70302936020	Lead	<1.0	5	ug/L
RE-12A		6/25/2024 09:42	7/9/2024 17:49	70302936021	Lead	<1.0	5	ug/L
RE-13A		6/25/2024 09:55	7/9/2024 17:51	70302936022	Lead	1.9	5	ug/L
RE-14A		6/25/2024 09:58	7/9/2024 17:52	70302936023	Lead	1.5	5	ug/L
RE-15A		6/25/2024 10:00	7/9/2024 17:54	70302936025	Lead	2.1	5	ug/L
RE-16A		6/25/2024 10:02	7/9/2024 17:55	70302936026	Lead	<1.0	5	ug/L
RE-17A		6/25/2024 10:04	7/9/2024 18:00	70302936027	Lead	1.9	5	ug/L
RE-18		6/25/2024 10:05	7/9/2024 18:02	70302936028	Lead	2.4	5	ug/L
RE-20		6/25/2024 10:22	7/9/2024 18:03	70302936030	Lead	2.1	5	ug/L
RE-21A		6/25/2024 10:24	7/9/2024 18:05	70302936031	Lead	2.1	5	ug/L
RE-22A		6/25/2024 10:26	7/9/2024 18:06	70302936032	Lead	2.0	5	ug/L
RE-23A		6/25/2024 10:28	7/9/2024 18:08	70302936033	Lead	2.9	5	ug/L
RE-24A		6/25/2024 10:30	7/9/2024 18:10	70302936034	Lead	1.6	5	ug/L
RE-25A		6/25/2024 10:32	7/9/2024 18:11	70302936035	Lead	3.8	5	ug/L
RE-26		6/25/2024 10:33	7/9/2024 18:19	70302936036	Lead	<1.0	5	ug/L
RE-27		6/25/2024 10:33	7/9/2024 18:24	70302936037	Lead	<1.0	5	ug/L
RE-28		6/25/2024 10:35	7/9/2024 18:28	70302936038	Lead	3.1	5	ug/L
RE-28A		6/25/2024 10:35	7/9/2024 18:30	70302936039	Lead	2.7	5	ug/L
RE-29A		6/25/2024 10:36	7/9/2024 18:31	70302936040	Lead	1.7	5	ug/L
RE-31	Room 156 Drinking Fountain	6/25/2024 10:40	7/9/2024 18:33	70302936041	Lead	5.2	5	ug/L
RE-34	Nurses Office Sink	6/25/2024 09:30	7/9/2024 18:38	70302936042	Lead	7.9	5	ug/L
RE-35		6/25/2024 09:45	7/9/2024 18:39	70302936043	Lead	<1.0	5	ug/L
RE-35A		6/25/2024 09:45	7/9/2024 18:41	70302936044	Lead	<1.0	5	ug/L
RE-36A	Kitchen Sink Near Door	6/25/2024 09:50	7/9/2024 18:42	70302936045	Lead	5.5	5	ug/L
RE-36B		6/25/2024 09:50	7/9/2024 18:44	70302936046	Lead	4.2	5	ug/L
RE-36C		6/25/2024 09:50	7/9/2024 18:46	70302936047	Lead	4.8	5	ug/L
RE-16B		6/25/2024 10:02	7/9/2024 18:47	70302936048	Lead	<1.0	5	ug/L
RE-18A		6/25/2024 10:05	7/9/2024 18:49	70302936049	Lead	<1.0	5	ug/L
RE-31A		6/25/2024 10:40	7/9/2024 19:48	70302936050	Lead	<1.0	5	ug/L

NYSDOH Action Level for Lead In Schools of 5 ppb