

Sample Identification # and Location	Location Info	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action	Units
VM37		6/25/2024 10:29	7/10/2024 15:35	70303004001	Lead	2.7	5	ug/L
VM42		6/25/2024 10:30	7/10/2024 15:40	70303004002	Lead	<1.0	5	ug/L
VM34	Faculty Lounge	6/25/2024 10:32	7/10/2024 15:41	70303004003	Lead	6.2	5	ug/L
VM31		6/25/2024 10:33	7/10/2024 15:43	70303004004	Lead	<1.0	5	ug/L
VM32		6/25/2024 10:34	7/10/2024 15:44	70303004005	Lead	<1.0	5	ug/L
VM27		6/25/2024 10:37	7/10/2024 15:46	70303004006	Lead	<1.0	5	ug/L
VM28		6/25/2024 10:38	7/10/2024 15:48	70303004007	Lead	<1.0	5	ug/L
VM106		6/25/2024 10:37	7/10/2024 15:49	70303004008	Lead	<1.0	5	ug/L
VM21		6/25/2024 10:41	7/10/2024 15:51	70303004009	Lead	2.1	5	ug/L
VM22		6/25/2024 10:41	7/10/2024 15:52	70303004010	Lead	<1.0	5	ug/L
VM23		6/25/2024 10:42	7/10/2024 15:54	70303004011	Lead	<1.0	5	ug/L
VM24		6/25/2024 10:42	7/10/2024 15:59	70303004012	Lead	4.9	5	ug/L
VM25		6/25/2024 10:43	7/10/2024 16:00	70303004013	Lead	3.2	5	ug/L
VM26		6/25/2024 10:43	7/10/2024 16:02	70303004014	Lead	1.7	5	ug/L
VM15		6/25/2024 10:46	7/10/2024 16:06	70303004015	Lead	<1.0	5	ug/L
VM9		6/25/2024 10:48	7/10/2024 16:11	70303004016	Lead	<1.0	5	ug/L
VM10		6/25/2024 10:49	7/10/2024 16:19	70303004017	Lead	<1.0	5	ug/L
VM8		6/25/2024 10:53	7/10/2024 16:20	70303004018	Lead	<1.0	5	ug/L
VM49		6/25/2024 10:57	7/10/2024 16:22	70303004019	Lead	<1.0	5	ug/L
VM50		6/25/2024 10:58	7/10/2024 16:24	70303004020	Lead	<1.0	5	ug/L
VM104		6/25/2024 11:01	7/10/2024 16:25	70303004021	Lead	<1.0	5	ug/L
VM105		6/25/2024 11:01	7/10/2024 16:27	70303004022	Lead	<1.0	5	ug/L
VM43	Board Room Sink	6/25/2024 11:03	7/11/2024 14:06	70303004023	Lead	232	5	ug/L

NYSDOH Action Level for Lead In Schools of 5 ppb